

**STATE OF ARKANSAS
OFFICE OF STATE PROCUREMENT
1509 West Seventh Street, Room 300
Little Rock, Arkansas 72201-4222
501-324-9316**

ADDENDUM 2

TO: Vendors Addressed
FROM: Tim O'Brien
DATE: October 16, 2015
SUBJECT: **SP-16-0095**

The following change(s) to the above-referenced Invitation for Bid have been made as designated below:

☒ Change of specification(s)
☒ Additional specification(s)
☐ Change of bid opening time and date
☐ Cancellation of bid
☐ Other

1. Replace Section 23 52 13:

Replace section 23 52 13 in its entirety (page 23 52 13-1 through page 23 52 13-5) with the attached revised section 23 52 13.

2. Additional Notes to Drawing M1.01:

Add the following notes to Drawing M1.01

- a. Contractor to provide new control wiring in existing conduit for combustion and gas valve controls.
- b. Contractor will be responsible for reconnecting 120V power to gas valve and pressure sensors.

The changes and additions referenced above by virtue of this addendum become a permanent addition to the above referenced Invitation for Bid. FAILURE TO RETURN THIS SIGNED ADDENDUM MAY RESULT IN REJECTION OF YOUR BID.

BIDS WILL BE ACCEPTED UNTIL THE TIME AND DATE SPECIFIED. THE BID ENVELOPE MUST BE SEALED AND SHOULD BE PROPERLY MARKED WITH THE BID NUMBER, DATE AND HOUR OF BID OPENING AND BIDDER'S RETURN ADDRESS. IT IS NOT NECESSARY TO RETURN "NO BIDS" TO THE OFFICE OF STATE PROCUREMENT.

If you have any questions please contact Tim O'Brien at Timothy.O'Brien@dfa.arkansas.gov or (501) 324-9320

Company: _____

Signature: _____

Date: _____