

State of Arkansas
OFFICE OF STATE PROCUREMENT
1509 West Seventh Street, Room 300
Little Rock, Arkansas 72201-4222
501-324-9316

ADDENDUM 2

TO: Vendors Addressed
FROM: Anna Hawthorne
DATE: May 4, 2016
SUBJECT: SP-16-0190; Air Conditioning Units

The following change(s) to the above-referenced Invitation for Bid have been made as designated below:

 X Change of Item Specifications

BID OPENING DATE AND TIME:

May 12, 2016 at 1:00 p.m. CDT (as indicated in Addendum 1)

CHANGE OF ITEM SPECIFICATIONS – SECTION 3

CURRENT ITEM SPECIFICATIONS:

3.1 AIR CONDITIONING UNITS

- All air conditioning units must be through-wall with heat strip and compatible with existing ICOM PTAC EMCS system
- All air conditioning units must not exceed measurements of 40"W x 15"H

CHANGE TO:

3.1 AIR CONDITIONING UNITS

- All air conditioning units must be through-wall with heat strip.
- All air conditioning units must be compatible with the existing InnComm System.
 - The InnComm is a wireless system that allows control of the temperature for the unit based on pre-sets. (current air conditioning units are Amana)
- All air conditioning units must fit a wall sleeve size of 42"W X 16"H.

The specifications by virtue of this addendum become a permanent addition to the above referenced Invitation for Bid. FAILURE TO RETURN THIS SIGNED ADDENDUM **MAY** RESULT IN REJECTION OF YOUR BID.

BIDS WILL BE ACCEPTED UNTIL THE TIME AND DATE SPECIFIED. THE BID ENVELOPE MUST BE SEALED AND SHOULD BE PROPERLY MARKED WITH THE BID NUMBER, DATE AND HOUR OF BID OPENING AND BIDDER'S RETURN ADDRESS. IT IS NOT NECESSARY TO RETURN "NO BIDS" TO THE OFFICE OF STATE PROCUREMENT.

If you have any questions please contact **Anna Hawthorne** at Anna.Hawthorne@dfa.arkansas.gov or 501-371-6054.

Company: _____

Signature: _____ Date: _____