



STATE OF ARKANSAS
OFFICE OF STATE PROCUREMENT
 1509 West 7th Street, Room 300
 Little Rock, Arkansas 72201-4222

ADDENDUM 1

TO: Vendors Addressed
 FROM: Judy Shirley, Buyer
 DATE: March 29, 2019
 SUBJECT: SP-19-0066 Incinerator

The following change(s) to the above-referenced IFB have been made as designated below:

- ☒ Change of specification(s)
- ☐ Additional specification(s)
- ☐ Change of bid opening time and date
- ☐ Cancellation of bid
- ☐ Other

BID OPENING DATE AND TIME

- Bid opening date and time shall remain unchanged.

CHANGE OF SPECIFICATIONS

- **Delete Section 2.7 (A) (2) and (3) (a – c)**

2. Fuel service **must** be natural gas.

(a) and (b) remain the same.

3. LNG fuel tank and all associated lines, tubing, and valves **must** have:

- a. Capacity adequate to meet demand of fuel consumption from vapor space preventing auto-refrigeration.
- b. Capacity adequate to fuel six (6) full-capacity burns per month.
- c. Minimum fifteen (15) second fuel shut-down should ignition fail.

- **Replace with the following:**

2.7 (A) (2)

2. Unit **must** be propane-fired.

*NOTE: Propane provider will supply all associated lines, tubing, and valves as required.

The specifications by virtue of this addendum become a permanent addition to the above referenced IFB. Failure to return this signed addendum may result in rejection of your proposal.

If you have any questions, please contact Judy Shirley at judy.shirley@dfa.arkansas.gov or (501) 324-9316.

Company: _____

Signature: _____

Date: _____